



Corrective Action Notice

School : JONES PC
Cost Center : 0001511201
Address : 1017 W 47TH STREET
LOS ANGELES, CA90037

Site Administrator : CHRISTIAN PANES
Complex Project Manager : ERNEST MCCOLLOUGH

Inspection Date : Dec 8, 2022

Inspection Type : Routine Safe School Inspection

Inspector : Ponce, Victor

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Dec 8, 2022	36121783	Lead Management	Repair areas of peeling or otherwise deteriorated paint surfaces and clean up paint debris. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .		ADMINISTRATION & CLRM BLDG, Playground Apparatus	Facilities	
Level 1	Dec 8, 2022	36121750	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.	Remove the portable ladder obstructing the pathway to the exit doors.	ADMINISTRATION & CLRM BLDG, Stage Corridor, Auditorium	School	
Level 2	Jan 7, 2023	36122202	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.	An excessive amount of paper decorations on the walls was observed during the inspection. The walls were covered entirely with decorative wallpaper.	ADMINISTRATION & CLRM BLDG, Room 4 and Room 13.	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Jan 7, 2023	36121715	Facilities and Equipment Maintenance	Repair/replace damaged or missing ceiling tile(s). Consult the Asbestos Management Plan prior to repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Place a service request for M&O to removed and replace stained ceiling tiles.	ADMINISTRATION & CLRM BLDG, Room K-2; Multi-purpose Room and Library	Facilities	
Level 2	Jan 7, 2023	36121729	Fire/Life Safety	Remove curtains that are not flame resistant.	The stage curtains need to be re-certified every five years. Place a service request to M&O for assistance.	ADMINISTRATION & CLRM BLDG, Stage Curtains, MPR	School	
Level 2	Jan 7, 2023	36121734	Facilities and Equipment Maintenance	Ensure all areas in the school are clean, well maintained and free of clutter.		ADMINISTRATION & CLRM BLDG, Office in the Library	School	
Level 2	Jan 7, 2023	36121778	Facilities and Equipment Maintenance	Repair/replace damaged or deteriorated playground surfacing materials. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .		ADMINISTRATION & CLRM BLDG,	Facilities	
Level 3	Mar 8, 2023	36121786	Injury and Illness Prevention	Conduct and document semi-annual safety inspections pursuant to Injury and Illness Prevention Program (IIPP). Maintain inspection records for at least 3 years.		ADMINISTRATION & CLRM BLDG,	School	
Level 3	Mar 8, 2023	36121771	Facilities and Equipment Maintenance	Ensure age appropriate use signs and playground safety rules are affixed to playground equipment. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Post the appropriate age signage for the playground apparatus.	ADMINISTRATION & CLRM BLDG,	Facilities	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 3	Mar 8, 2023	36121707	Facilities and Equipment Maintenance	Post valid operating permit near air compressor, air pressure tank, elevator, boiler, or other equipment subject to Occupational Safety and Health Administration (OSHA) permitting.		ADMINISTRATION & CLRM BLDG, Main Building	Facilities	