



# Corrective Action Notice

<b>School :</b>	ADAMS MS	<b>Site Administrator :</b>	GABRIEL ARREGUIN
<b>Cost Center :</b>	0001800901	<b>Complex Project Manager :</b>	Luis Quinonez
<b>Address :</b>	151 W 30TH ST LOS ANGELES, CA90007		
<b>Inspection Date :</b>	Mar 13, 2023	<b>Inspection Type :</b>	Routine Safe School Inspection
<b>Inspector :</b>	Ponce, Victor		

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Mar 13, 2023	36449801	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.		Classroom B-6	School	
Level 1	Mar 13, 2023	36449804	Fire/Life Safety	Maintain a minimum 3-foot clearance around fire extinguishers, fire hoses, pull stations and sprinkler control valves.		Classroom M-133	School	
Level 1	Mar 13, 2023	36449773	Lead Management	Repair areas of peeling or otherwise deteriorated paint surfaces and clean up paint debris. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .	Stabilize peeling paint at the top and bottom of the whiteboard.	Classroom 222	Facilities	
Level 2	Apr 12, 2023	36449808	Injury and Illness Prevention	Remove household appliances (e.g., toaster/oven, microwave oven, refrigerator, coffee machine, and heater) or other unauthorized electrical appliances from classrooms pursuant to Bulletin 6436.		Classrooms 5; 203; 303-B; & 309	School	
Level 2	Apr 12, 2023	36449865	Emergency Procedures (Integrated Safe School Plan)	Ensure cargo storage containers are placed on concrete pads at least 20 feet from the property line or any building and a minimum of a 72-hour supply of emergency water, food, and other emergency supplies and equipment is provided.	The emergency bin is missing various emergency supplies and a 72-hour food supply. Please refer to REF 5451.1 for a complete list of emergency supplies required.	Emergency Bin	School	
Level 2	Apr 12, 2023	36449777	Chemical Safety	Ensure eyewash stations and shower equipment are activated at least monthly to verify proper operations and maintain written documentation for 3 years.		Classroom 13	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Apr 12, 2023	36449797	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.		Classrooms 5; 8; 14; 204; 205; 206; 303-A; 306; 308; & 309	School	
Level 2	Apr 12, 2023	36449786	Fire/Life Safety	Provide visible exit signs or directional signs for all exit doors and escape pathways. Ensure illuminated exit signs are on at all times. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .		North Cafeteria Exit; Girls Gym; & Auditorium	School	
Level 2	Apr 12, 2023	36449835	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .	Place service to repair the damaged wall near the curtain pulley.	Backstage area, south side	Facilities	
Level 2	Apr 12, 2023	36449850	Facilities and Equipment Maintenance	Maintain a minimum 3-foot clearance around all electrical equipment (e.g., electrical panels, switchgear, transformers).		Storage room between Classroom 13 & 14.	School	
Level 2	Apr 12, 2023	36449816	Injury and Illness Prevention	Ensure extension cords, outlet multipliers and surge protectors are not used in series.		Classroom 311 & Classroom 314	School	
Level 2	Apr 12, 2023	36449814	Injury and Illness Prevention	Ensure flexible extension cords and cables are not used in place of permanent wiring.		Classroom 424	School	
Level 2	Apr 12, 2023	36449858	Emergency Procedures (Integrated Safe School Plan)	Remove all materials and objects stored on top of cabinets or upper shelves unless such objects are fastened to the shelf or otherwise restrained from falling.		Classrooms 205; 209; 306; & 308	School	
Level 3	Jun 11, 2023	36449845	Facilities and Equipment Maintenance	Ensure tree canopies are adequately raised, plants are adequately trimmed, and landscape is free of tripping hazards or other obvious hazards. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .		Near the corner of Hill and 30th Street	Facilities	
Level 3	Jun 11, 2023	36449784	Asbestos Management	Ensure 6-Month Visual Surveillance is conducted by the Facilities Environmental Technical Unit (FETU) and results are included in the school Asbestos Management Plan. For assistance, contact FETU at (213) 745-1450.			Facilities	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 3	Jun 11, 2023	36449780	Chemical Safety	Provide all employees with annual Hazard Communication training on hazardous chemicals used in their respective work areas. Employees must be retrained when new hazards are introduced into the workplace.			School	
Level 3	Jun 11, 2023	36449819	Injury and Illness Prevention	Provide and maintain records of annual Injury and Illness Prevention Program (IIPP) training. Maintain training records on-site for 3 years.			School	
Level 3	Jun 11, 2023	36449821	Injury and Illness Prevention	Conduct and document semi-annual safety inspections pursuant to Injury and Illness Prevention Program (IIPP). Maintain inspection records for at least 3 years.			School	