



# Corrective Action Notice

**School :** ARAGON EL  
**Cost Center :** 0001217801  
**Address :** 1118 ARAGON AVE  
 LOS ANGELES, CA90065

**Site Administrator :** CLAUDIA VELA  
**Complex Project Manager :** Ray Barreras

**Inspection Date :** Feb 10, 2023  
**Inspector :** Logan, Sean

**Inspection Type :** Routine Safe School Inspection

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Feb 10, 2023	36337758	Fire/Life Safety	Maintain a minimum 3-foot clearance around fire extinguishers, fire hoses, pull stations and sprinkler control valves.		Cage adjacent to the parking lot	School	
Level 1	Feb 10, 2023	36337686	Chemical Safety	Do not use chemicals unless approved for District use by OEHS. Refer to the OEHS website at <a href="https://achieve.lausd.net/oehschemeval">https://achieve.lausd.net/oehschemeval</a> (see Product Review) or contact OEHS at (213) 241-3199 for assistance.		Room 19; Room 17	School	
Level 1	Feb 10, 2023	36337655	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.		Music room	School	
Level 2	Mar 12, 2023	36337684	Emergency Procedures (Integrated Safe School Plan)	Remove all materials and objects stored on top of cabinets or upper shelves unless such objects are fastened to the shelf or otherwise restrained from falling.		Room 27; Room 22; Room 19 (staff workroom); Room 2; Music Room; & Main Office	School	
Level 2	Mar 12, 2023	36337665	Facilities and Equipment Maintenance	Maintain a minimum 3-foot clearance around all electrical equipment (e.g., electrical panels, switchgear, transformers).		Cafeteria	School	
Level 2	Mar 12, 2023	36337678	Fire/Life Safety	Conduct and document monthly visual inspection of portable fire extinguishers. Note inspection date on the service tag and the Fire Log Book.		Throughout Campus	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Mar 12, 2023	36337691	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .	The sink cabinet is missing a handle.	Teacher's Lounge	Facilities	
Level 3	May 11, 2023	36337765	Facilities and Equipment Maintenance	Post valid operating permit near air compressor, air pressure tank, elevator, boiler, or other equipment subject to Occupational Safety and Health Administration (OSHA) permitting.		Main building elevator	Facilities	
Level 3	May 11, 2023	36337701	Injury and Illness Prevention	Conduct and document semi-annual safety inspections pursuant to Injury and Illness Prevention Program (IIPP). Maintain inspection records for at least 3 years.			School	
Level 3	May 11, 2023	36337698	Fire/Life Safety	Post signs in a conspicuous place near the main exit doorway of assembly rooms indicating maximum occupant load and usage.		Library	Facilities	

#### List of Open Deficiencies in this site

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Dec 20, 2015	28333235	Injury and Illness Prevention	Post a copy of the Injury and Illness Prevention Program (IIPP) Summary in a conspicuous area.	Post a copy of the Injury and Illness Prevention Program (IIPP) Summary in a conspicuous area.		School	
Level 3	Feb 18, 2016	28333231	Injury and Illness Prevention	Conduct and document semi-annual safety inspections pursuant to Injury and Illness Prevention Program (IIPP). Maintain inspection records for at least 3 years.	Conduct and document semi-annual safety inspections pursuant to Injury and Illness Prevention Program (IIPP). Maintain inspection records for at least 3 years.		School	
Level 3	Feb 18, 2016	28333333	Facilities and Equipment Maintenance	Repair/replace burned out light bulbs (lamps). If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .	Repair/replace burned out light bulbs (lamps). If necessary, place a service call to the Maintenance and Operations Service Call Unit at (213) 745-1600.	2178_Aragon ES_Room 19	School	
Level 3	Feb 18, 2016	28333237	Chemical Safety	Implement a Hazard Communication Program pursuant to Cal/OSHA requirements. Obtain a copy of the District's Hazard Communication Program at <a href="https://bit.ly/LAUSDHazardCommunicationPlan">https://bit.ly/LAUSDHazardCommunicationPlan</a> or contact OEHS at (213) 241-3199.	Implement a Hazard Communication Program pursuant to Cal/OSHA requirements. To obtain a copy of the District's Hazard Communication Program, contact OEHS at (213) 241-3199.		School	

**List of Open Deficiencies in this site**

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 3	Feb 18, 2016	28333239	Chemical Safety	Provide all employees with annual Hazard Communication training on hazardous chemicals used in their respective work areas. Employees must be retrained when new hazards are introduced into the workplace.	Provide employees with annual Hazard Communication training on hazardous chemicals used in their respective work areas. Employees must be retrained when new hazards are introduced into the workplace.		School	
Level 3	Feb 18, 2016	28333234	Injury and Illness Prevention	Establish a School Safety Committee that meets at least quarterly and documents meeting minutes. Responsibilities include: review inspection findings, alleged hazardous conditions and incident reports to identify safety issues and prevent recurrence.	Establish a School Safety Committee that meets at least quarterly and documents meeting minutes. Responsibilities include: review inspection findings, alleged hazardous conditions and incident reports to identify safety issues and prevent recurrence.		School	