



Corrective Action Notice

School : BEACHY EL
Cost Center : 0001232901
Address : 9757 BEACHY AVE
 ARLETA, CA91331

Site Administrator : LISA DACHS-ORNELAS
Complex Project Manager : Richard Craig

Inspection Date : Feb 9, 2023
Inspector : Oguine, Debra

Inspection Type : Routine Safe School Inspection

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Feb 9, 2023	36335437	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.	Relocate all items blocking doors.	Room 20; Room 32; Room 39	School	
Level 1	Feb 9, 2023	36335482	Injury and Illness Prevention	Ensure proper guarding is provided and maintained on all equipment to prevent injury to operators.	Install safety latch on paper cutters.	Workroom by Room 41	Facilities	
Level 1	Feb 9, 2023	36335526	Fire/Life Safety	Provide temporary guarding or other controls for floor openings, excavations and damaged walking surfaces to prevent falls. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair/remove wood trim protruding on the walkway, to prevent trip and fall hazards.	Adjacent to Room 8	Facilities	
Level 1	Feb 9, 2023	36335378	Injury and Illness Prevention	Ensure that contaminated sharps are disposed in approved containers. Sharps containers must be replaced when damaged or filled to capacity. For assistance, contact Nursing Services at (213) 202-7580.	Replace the missing sharps container in the Health Office.	Health Office	School	
Level 1	Feb 9, 2023	36335415	Lead Management	Repair areas of peeling or otherwise deteriorated paint surfaces and clean up paint debris. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair peeling paint.	Auditorium Hallways by Stage	Facilities	
Level 1	Feb 9, 2023	36335536	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.	Clear all objects blocking emergency egress windows.	Room 5	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Mar 11, 2023	36335534	Facilities and Equipment Maintenance	Maintain a minimum 3-foot clearance around all electrical equipment (e.g., electrical panels, switchgear, transformers).	Relocate items blocking electrical panels.	Room 13; Room 3	School	
Level 2	Mar 11, 2023	36335431	Injury and Illness Prevention	Ensure flexible extension cords and cables are not used in place of permanent wiring.	Do not use extension cords as permanent wiring. Unplug after each use or plug equipment directly into the wall.	Room 22	School	
Level 2	Mar 11, 2023	36335355	Pest Management	Ensure air curtains and fly fans are turned on during food preparation and service.	Repair non-working fly fan.	Kitchen	Food Services	
Level 2	Mar 11, 2023	36335405	Facilities and Equipment Maintenance	Repair/replace damaged or missing ceiling tile(s). Consult the Asbestos Management Plan prior to repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .		Auditorium Hallways by Stage	Facilities	
Level 2	Mar 11, 2023	36335476	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.	Remove paper decorations covering the entire door surface.	Room 3	School	
Level 2	Mar 11, 2023	36335472	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.	Remove paper decorations hanging by light fixtures.	Room 41	School	
Level 3	May 10, 2023	36335351	Chemical Safety	Provide all employees with annual Hazard Communication training on hazardous chemicals used in their respective work areas. Employees must be retrained when new hazards are introduced into the workplace.	Maintain documentation of annual Hazard Communication training.	Main Office	School	
Level 3	May 10, 2023	36335446	Facilities and Equipment Maintenance	Ensure age appropriate use signs and playground safety rules are affixed to playground equipment. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Replace missing safety rules on the play apparatus.	Playground Equipment	Facilities	