



Corrective Action Notice

School : DACOTAH ST EEC
Cost Center : 0001951201
Address : 3142 LYDIA DR
 LOS ANGELES, CA90023
Inspection Date : Feb 7, 2023
Inspector : Shinwari, Maiwand
Site Administrator : SHAMEKA DEVON ROBINSON-
Complex Project Manager : Ruben Soria
Inspection Type : Routine Safe School Inspection

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Feb 7, 2023	36328608	Facilities and Equipment Maintenance	Ensure playground equipment and matting complies with American Society for Testing and Materials (ASTM) standards and Consumer Products Safety Commission (CPSC) guidelines.	Replace or repair the playground apparatus matting and rusted slide poles.		Facilities	
Level 1	Feb 7, 2023	36328652	Injury and Illness Prevention	Conduct and document semi-annual safety inspections pursuant to Injury and Illness Prevention Program (IIPP). Maintain inspection records for at least 3 years.			School	
Level 1	Feb 7, 2023	36328729	Lead Management	Repair areas of peeling or otherwise deteriorated paint surfaces and clean up paint debris. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Stabilize peeling paint on the pink wall south of the apparatus.		Facilities	
Level 1	Feb 7, 2023	36328855	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.	the Emergency Window is bolted and not openable.	Classroom 1; 3 and Main Office	School	
Level 2	Mar 9, 2023	36328722	Fire/Life Safety	Conduct and document monthly visual inspection of portable fire extinguishers. Note inspection date on the service tag and the Fire Log Book.			School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Mar 9, 2023	36328768	Chemical Safety	Dispose of hazardous waste generated at schools at least every 180 days. To request pickup and disposal services, submit a work order to https://facapps.lausd.net/mwkiosk and complete a request form at https://bit.ly/LAUSDHazardousWastePickupRequest . For assistance, contact OEHS at (213) 241-3199.	Dispose of expired hand sanitizers		School	
Level 2	Mar 9, 2023	36328717	Fire/Life Safety	Conduct and document monthly inspections of fire alarms in the Fire Log Book to ensure they are in good working order. Ensure a different pull station is tested each month.			School	
Level 3	May 8, 2023	36328875	Asbestos Management	Ensure 6-Month Visual Surveillance is conducted by the Facilities Environmental Technical Unit (FETU) and results are included in the school Asbestos Management Plan. For assistance, contact FETU at (213) 745-1450.		Main Office	Facilities	