



# Corrective Action Notice

<b>School :</b>	HILLSIDE EL	<b>Site Administrator :</b>	RICHARD YCAZA
<b>Cost Center :</b>	0001453401	<b>Complex Project Manager :</b>	Ray Barreras
<b>Address :</b>	120 E AVE 35 LOS ANGELES, CA90031		
<b>Inspection Date :</b>	Jan 25, 2023	<b>Inspection Type :</b>	Routine Safe School Inspection
<b>Inspector :</b>	Logan, Sean		

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Jan 25, 2023	36274749	Chemical Safety	Do not use chemicals unless approved for District use by OEHS. Refer to the OEHS website at <a href="https://achieve.lausd.net/oehschemeval">https://achieve.lausd.net/oehschemeval</a> (see Product Review) or contact OEHS at (213) 241-3199 for assistance.		Room 9 & Room 17	School	
Level 2	Feb 24, 2023	36274742	Facilities and Equipment Maintenance	Repair/replace damaged or missing ceiling tile(s). Consult the Asbestos Management Plan prior to repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .	Replace the water-stained ceiling titles.	Room 17 & Room 202	Facilities	
Level 2	Feb 24, 2023	36274739	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.		Library	School	
Level 3	Apr 25, 2023	36274754	Fire/Life Safety	Post signs in a conspicuous place near the main exit doorway of assembly rooms indicating maximum occupant load and usage.		Library	Facilities	
Level 3	Apr 25, 2023	36274765	Chemical Safety	Provide all employees with annual Hazard Communication training on hazardous chemicals used in their respective work areas. Employees must be retrained when new hazards are introduced into the workplace.			School	