



Corrective Action Notice

School : LASSEN EL
Cost Center : 0001479001
Address : 15017 SUPERIOR ST
NORTH HILLS, CA91343

Site Administrator : UCHENNA OKEREKE
Complex Project Manager : Mauricio Pinto

Inspection Date : Feb 2, 2023
Inspector : Pham, Trang
Inspection Type : Routine Safe School Inspection

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Feb 2, 2023	36317978	Fire/Life Safety	Ensure that instructions on how to use the Automated External Defibrillator (AED) are posted next to every AED. The AED Signage must be visible with clear instructions that are no less than 14-point font size.	Ensure the AED alarm functions when opening the AED box.	Nurse's office	School	
Level 2	Mar 4, 2023	36318290	Facilities and Equipment Maintenance	Repair/replace damaged or deteriorated playground surfacing materials. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	The 5-12-year-old playground equipment has been restricted due to the playground surfacing condition. Service requests have been placed to conduct the proper repairs.	Main Yard Playground	Facilities	