



Corrective Action Notice

School : SATICOY EL
Cost Center : 0001656501
Address : 7850 ETHEL AVE
 N HOLLYWOOD, CA91605

Site Administrator : MARIA AWAKIAN
Complex Project Manager : David Hokanson

Inspection Date : Jan 26, 2023
Inspector : Sridhar, Abiram
Inspection Type : Routine Safe School Inspection

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Jan 26, 2023	36293947	Fire/Life Safety	Ensure that school administrators and staff receive annual AED and CPR training that includes information about sudden cardiac arrest, the school emergency response plan, location of AEDs and how to use an AED.		Health Office	School	
Level 1	Jan 26, 2023	36293926	Injury and Illness Prevention	Maintain a student medication log, doctor protocols and dispensing log in the Nurse's office.		Health Office	School	
Level 1	Jan 26, 2023	36293971	COVID-19 Compliance	Ensure compliance with the current COVID-19 Containment, Response, and Control Plan.	Complete and post Site Specific Planning Form.	Main Office.	School	
Level 1	Jan 26, 2023	36293925	Injury and Illness Prevention	Establish, implement, and maintain Heat Illness Prevention Program using the OEHS template and update it at least annually. For assistance, contact OEHS at (213) 241- 3199.		Main Office	School	
Level 1	Jan 26, 2023	36293859	Fire/Life Safety	Remove all objects that may conceal or obscure exit signs.	Ensure emergency exits are not blocked.	Room 9 ; Room 12 ; Room 18 ; Room 15 ; Room 25	School	
Level 2	Feb 25, 2023	36293909	Indoor Environment	Ensure rooms are properly maintained to minimize objectionable odors.	Remove the air freshener from the classroom.	Room 10	School	
Level 2	Feb 25, 2023	36293614	Injury and Illness Prevention	Remove household appliances (e.g., toaster/oven, microwave oven, refrigerator, coffee machine, and heater) or other unauthorized electrical appliances from classrooms pursuant to Bulletin 6436.		Room 1; Room 5; PM Office; Room 13; Room 26	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Feb 25, 2023	36294005	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Replace/repair the volleyball court nets that are torn and hanging.	Playground	Facilities	
Level 2	Feb 25, 2023	36293945	Fire/Life Safety	Each school or office shall create an AED Binder to be placed on top of each AED's cabinet(s) and include the following inside the binder: * Completed CPR/AED Emergency Response Site Plan * Bulletin 4480.2 Policy and Procedure for the Acquisition and Use of AEDs.		Health Office	School	
Level 2	Feb 25, 2023	36294011	Emergency Procedures (Integrated Safe School Plan)	Ensure cargo storage containers are placed on concrete pads at least 20 feet from the property line or any building and a minimum of a 72-hour supply of emergency water, food, and other emergency supplies and equipment is provided.	Ensure to label three water containers to show the water treatment date and expiration date.	Emergency Bin	School	
Level 2	Feb 25, 2023	36293900	Fire/Life Safety	Replace plastic or rubber waste receptacles with metal or metal-lined waste receptacles.	Remove used soda cans from the classroom to prevent pests.	Throughout Site	School	
Level 2	Feb 25, 2023	36293804	Fire/Life Safety	Maintain aisles and walkways free of obstruction or tripping hazards.		Throughout Site	School	
Level 2	Feb 25, 2023	36293806	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.		Throughout Site	School	
Level 2	Feb 25, 2023	36293916	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.	Remove wet paper towels rolled into balls and stuck to restroom ceilings.	Restrooms throughout site.	School	
Level 2	Feb 25, 2023	36293890	Fire/Life Safety	Conduct and document monthly visual inspection of portable fire extinguishers. Note inspection date on the service tag and the Fire Log Book.		Room 23; J Building Workroom; Room 29; Room 30; Room K3	School	
Level 2	Feb 25, 2023	36293672	Emergency Procedures (Integrated Safe School Plan)	Remove all materials and objects stored on top of cabinets or upper shelves unless such objects are fastened to the shelf or otherwise restrained from falling.		Throughout Site	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Feb 25, 2023	36293874	Facilities and Equipment Maintenance	Repair/replace damaged or missing ceiling tile(s). Consult the Asbestos Management Plan prior to repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .		Throughout Site	Facilities	
Level 2	Feb 26, 2023	36301274	Facilities and Equipment Maintenance	Maintain a minimum 3-foot clearance around all electrical equipment (e.g., electrical panels, switchgear, transformers).	Remove stored items from Electrical Room.	CLRM BLDG E, Electrical Room	School	
Level 2	Feb 25, 2023	36293826	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Stabilize cracks found on the upper wall in the classroom.	Room 5	Facilities	
Level 2	Feb 25, 2023	36293834	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Remove duct tape from the water lines leading to the sink.	Restroom in Room 5	Facilities	
Level 2	Feb 25, 2023	36293921	Facilities and Equipment Maintenance	Ensure all areas within the school have adequate indoor lighting. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Replace non-working light bulbs.	Throughout site	Facilities	
Level 2	Feb 25, 2023	36294001	Facilities and Equipment Maintenance	Ensure playground equipment and matting complies with American Society for Testing and Materials (ASTM) standards and Consumer Products Safety Commission (CPSC) guidelines.	Install the missing screw in the playground equipment.	Playground	Facilities	
Level 2	Feb 25, 2023	36293996	Facilities and Equipment Maintenance	Repair/replace damaged or deteriorated playground surfacing materials. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .		Playground	Facilities	
Level 3	Apr 26, 2023	36293927	Injury and Illness Prevention	Provide and maintain records of annual Injury and Illness Prevention Program (IIPP) training. Maintain training records on-site for 3 years.		Main Office	School	
Level 3	Apr 26, 2023	36293960	Chemical Safety	Provide all employees with annual Hazard Communication training on hazardous chemicals used in their respective work areas. Employees must be retrained when new hazards are introduced into the workplace.		Main Office	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 3	Apr 26, 2023	36293950	Asbestos Management	Ensure 6-Month Visual Surveillance is conducted by the Facilities Environmental Technical Unit (FETU) and results are included in the school Asbestos Management Plan. For assistance, contact FETU at (213) 745-1450.		Main Office	Facilities	
Level 3	Apr 26, 2023	36293952	Asbestos Management	Ensure all employees engaged in Class I through Class IV asbestos work activities have received the required training.		Main Office	Facilities	
Level 3	Apr 26, 2023	36293816	Emergency Procedures (Integrated Safe School Plan)	Provide seismic bracing for furniture, equipment and appliances.	Provide seismic bracing for shelves.	Textbook Room; Administration Workroom	Facilities	
Level 3	Apr 26, 2023	36293932	Injury and Illness Prevention	Maintain a Sharps Injury Log of each employee exposure incident involving a sharp (e.i. needle, scalpel, lancet, etc). Records must be maintained for 5 years.		Health Office	School	
Level 3	Apr 26, 2023	36293937	Pest Management	Ensure all parents and staff have recieved a copy of the Annual Pesticide Use Notification and the Approved Pesticide List of products that may be used during the school year. Maintain a current list of parents/guardians that have requested a 72-hour advance notification.		Main Office	School	
Level 3	Apr 26, 2023	36293940	Injury and Illness Prevention	Maintain and implement a written Bloodborne Pathogen Exposure Control Plan to minimize exposure to bloodborne pathogens pursuant to Title 8 CCR. (See School Nurse for requirements.)		Health Office	School	