



Corrective Action Notice

School : SOUTH GATE MS
Cost Center : 0001837701
Address : 4100 FIRESTONE BLVD
 SOUTH GATE, CA90280
Site Administrator : SALVADOR TORRES
Complex Project Manager : Pablo Castillo
Inspection Date : Feb 7, 2023
Inspection Type : Routine Safe School Inspection
Inspector : Logan, Sean

| Priority | Due Date | Deficiency# | Category | Corrective Action | Comments | Location | Resp. Party | Certify |
|----------|-------------|-------------|--|--|--|--------------------|-------------|---------|
| Level 1 | Feb 7, 2023 | 36328813 | Chemical Safety | Do not use chemicals unless approved for District use by OEHS. Refer to the OEHS website at https://achieve.lausd.net/oehschemeval (see Product Review) or contact OEHS at (213) 241-3199 for assistance. | | Music Room | School | |
| Level 2 | Mar 9, 2023 | 36328824 | Facilities and Equipment Maintenance | Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ . | The handrail on the stairs leading to the stage has broken off the wall. | Front of the stage | Facilities | |
| Level 2 | Mar 9, 2023 | 36328785 | Emergency Procedures (Integrated Safe School Plan) | Remove all materials and objects stored on top of cabinets or upper shelves unless such objects are fastened to the shelf or otherwise restrained from falling. | | Throughout Campus | School | |
| Level 2 | Mar 9, 2023 | 36328769 | Fire/Life Safety | Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters. | | Throughout Campus | School | |
| Level 2 | Mar 9, 2023 | 36328812 | Facilities and Equipment Maintenance | Maintain a minimum 3-foot clearance around all electrical equipment (e.g., electrical panels, switchgear, transformers). | | Music Room | School | |

| Priority | Due Date | Deficiency# | Category | Corrective Action | Comments | Location | Resp. Party | Certify |
|----------|-------------|-------------|--|---|----------|----------------------|-------------|---------|
| Level 3 | May 8, 2023 | 36328836 | Injury and Illness Prevention | Conduct and document semi-annual safety inspections pursuant to Injury and Illness Prevention Program (IIPP). Maintain inspection records for at least 3 years. | | | School | |
| Level 3 | May 8, 2023 | 36328831 | Emergency Procedures (Integrated Safe School Plan) | Provide seismic bracing for furniture, equipment and appliances. | | Books in the library | Facilities | |