



Corrective Action Notice

School : VALERIO EL
Cost Center : 0001738401
Address : 15035 VALERIO ST
 VAN NUYS, CA91405

Site Administrator : ANAIT VARDOUMIAN
Complex Project Manager : Richard Craig

Inspection Date : Feb 1, 2023
Inspector : Oguine, Debra

Inspection Type : Routine Safe School Inspection

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Feb 1, 2023	36315166	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.	Clear all objects blocking doors/exit pathways.	K2	School	
Level 1	Feb 1, 2023	36315337	Lead Management	Repair areas of peeling or otherwise deteriorated paint surfaces and clean up paint debris. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair peeling /cracking paint on interior walls and exterior stairway and hand rails.	Room 44	Facilities	
Level 2	Mar 3, 2023	36315248	Facilities and Equipment Maintenance	Repair/replace damaged or missing flooring. Consult the Asbestos Management Plan prior to repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair broken floor tile.	Room 41	Facilities	
Level 2	Mar 3, 2023	36315344	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair broken/loose interior wood trim on the south upper wall by the door.	Room 44	Facilities	
Level 2	Mar 3, 2023	36315363	Facilities and Equipment Maintenance	Repair/replace damaged or missing ceiling tile(s). Consult the Asbestos Management Plan prior to repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Replace missing/damaged ceiling tiles.	Room 44; Hallway by Library; Storeroom by Auditorium Stage	Facilities	
Level 2	Mar 3, 2023	36315235	Pest Management	Ensure air curtains and fly fans are turned on during food preparation and service.	Repair non-working fly fan.	Primary Center Kitchen	Food Services	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Mar 3, 2023	36315211	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair non-working sink faucet.	Girls' Restroom by Room 5P	Facilities	
Level 2	Mar 3, 2023	36315317	Facilities and Equipment Maintenance	Provide approved covers for all electrical outlets, switch plates, pull boxes, and junction boxes. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair damaged electrical outlet.	Room 39 East Wall	Facilities	
Level 2	Mar 3, 2023	36315218	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Repair the non-working dryer.	Boys' Restroom by Room 5P	Facilities	
Level 3	May 2, 2023	36315188	Facilities and Equipment Maintenance	Ensure age appropriate use signs and playground safety rules are affixed to playground equipment. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Replace missing playground safety rules on the apparatus.	Primary Center Play yard; Special Education Preschool Play Yard	Facilities	
Level 3	May 2, 2023	36315320	Facilities and Equipment Maintenance	Repair/replace burned out light bulbs (lamps). If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Replace burned out light bulb.	Room 39	School	
Level 3	May 2, 2023	36315156	Facilities and Equipment Maintenance	Ensure age appropriate use signs and playground safety rules are affixed to playground equipment. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at https://facapps.lausd.net/oehs/ .	Affix age limit signs and playground safety rules on playground equipment.	Main Yard	Facilities	
Level 3	May 2, 2023	36315278	Injury and Illness Prevention	Maintain a Sharps Injury Log of each employee exposure incident involving a sharp (e.i. needle, scalpel, lancet, etc). Records must be maintained for 5 years.	Maintain a Sharps Injury Log.	Health Office	School	

List of Open Deficiencies in this site

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Feb 19, 2016	28340030	Injury and Illness Prevention	Ensure proper guarding is provided and maintained on all equipment to prevent injury to operators.	Need safety latch on paper cutter.	7384_Valerio Street EL_ Faculty Workroom	Facilities	