



# Corrective Action Notice

**School :** 42ND ST EL  
**Cost Center :** 0001395901  
**Address :** 4231 4TH AVE.  
LOS ANGELES, CA90008

**Site Administrator :**  
**Complex Project Manager :** Ray Barreras

**Inspection Date :** Jan 17, 2023  
**Inspector :** Kefelegn, Yonathan

**Inspection Type :** Routine Safe School Inspection

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 1	Jan 17, 2023	36234910	Fire/Life Safety	Maintain exit pathways free of obstructions to ensure safe egress.	Blocked egress windows	Room 15; Room 16; Room 22; Room 23; B15; B16; Library; Work Room; Nurse's Office	School	
Level 2	Feb 16, 2023	36234926	Chemical Safety	Maintain current Safety Data Sheets (SDS) for each hazardous substance used on site.		Hopper Room	School	
Level 2	Feb 16, 2023	36234932	Emergency Procedures (Integrated Safe School Plan)	Remove all materials and objects stored on top of cabinets or upper shelves unless such objects are fastened to the shelf or otherwise restrained from falling.		Room 15; Room 23; B16; Work Room; B3	School	
Level 2	Feb 16, 2023	36234916	Fire/Life Safety	Conduct and document monthly visual inspection of portable fire extinguishers. Note inspection date on the service tag and the Fire Log Book.		Faculty Lounge; Work Room; Room 3; Room 10; Computer Lab	School	
Level 2	Feb 16, 2023	36234905	Facilities and Equipment Maintenance	Ensure all areas in the school are clean, well maintained and free of clutter.		Hopper Room; Auditorium Storage Room; Library; Computer Lab; Nurse's Office	School	
Level 2	Feb 16, 2023	36234879	Injury and Illness Prevention	Ensure flexible extension cords and cables are not used in place of permanent wiring.		Room 15, B15	School	

Priority	Due Date	Deficiency#	Category	Corrective Action	Comments	Location	Resp. Party	Certify
Level 2	Feb 16, 2023	36234942	Fire/Life Safety	Remove combustible materials (e.g. paper decorations, hanging mobiles) from exit doors, ceilings, electrical panels, light fixtures, fire sprinklers and heaters.		Room 22; B15; B16; Library	School	
Level 2	Feb 16, 2023	36234933	Facilities and Equipment Maintenance	Maintain a minimum 3-foot clearance around all electrical equipment (e.g., electrical panels, switchgear, transformers).		Auditorium Storage Room; Work Room; Room 3	School	
Level 2	Feb 16, 2023	36234894	Facilities and Equipment Maintenance	Ensure campus grounds and equipment are maintained in good repair. If necessary, submit a service request to the Maintenance and Operations Maximo Kiosk at <a href="https://facapps.lausd.net/oehs/">https://facapps.lausd.net/oehs/</a> .	Repair 2 concrete covers on blacktop	ASPHALT COURTS/ PLAYGROUND - 42ND ST EL - PLAYGROUND, Adjacent to play structure; East side of play area	Facilities	
Level 3	Apr 17, 2023	36234875	Injury and Illness Prevention	Prepare and implement an Injury and Illness Prevention Program (IIPP) using the OEHS "IIPP Template," and update at least annually in accordance with BUL-3772.3. For assistance, contact OEHS at (213) 241-3199.			School	
Level 3	Apr 17, 2023	36234873	Injury and Illness Prevention	Maintain and implement a written Bloodborne Pathogen Exposure Control Plan to minimize exposure to bloodborne pathogens pursuant to Title 8 CCR. (See School Nurse for requirements.)			School	
Level 3	Apr 17, 2023	36234922	Chemical Safety	Implement a Hazard Communication Program pursuant to Cal/OSHA requirements. Obtain a copy of the District's Hazard Communication Program at <a href="https://bit.ly/LAUSDHazardCommunicationPlan">https://bit.ly/LAUSDHazardCommunicationPlan</a> or contact OEHS at (213) 241-3199.			School	